



ROSS VALLEY SANITARY DISTRICT

2960 Kerner Blvd
San Rafael, CA 94901
(415) 259-2949 ~ rvsd.org

For Immediate Release

December 24, 2010

SANITARY SEWER OVERFLOW UPDATES

Sewer Spill Update for December 17-18 Event Kentfield - College Avenue Area

Updated 12/24/10

Sewer spill caused by construction debris in sewer system was partially contained and was mitigated by mid-afternoon 12/18. Cleanup was wrapped up on Monday morning, 12/20. The total size of this spill was 842,000 gallons with 105,000 recovered. All required notifications were met or exceeded.

Sewer Spill Update for December 22 Event Kentfield Force Main in Berm Along Corte Madera Creek

Updated 12/24/10

Sewer spill caused by Techite pipe material failure was mitigated late on 12/22. Sewer spill was partially contained and cleanup should be complete on 12/24. Three temporary bypasses have been set up on Magnolia Avenue, El Portal and on the berm located next to Corte Madera Creek while repairs are being made. The repair work will be completed and the Kentfield Pump Station brought back online on 12/24 thanks to around-the-clock work by Maggiora-Ghilotti Construction Company. Please drive slowly on Magnolia and El Portal when passing our bypasses. Traffic delays should be minimal. The total size of this spill was 1.8 million gallons with 300,000 recovered. All required notifications were met or exceeded.